

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/ 244

Dated: 23/05/2022

To,

The Assistant Engineer (E),
Sub Div – 1 Education Divn M 1 (N),
PWD GNCT, Govt. of Delhi,
ITI Campus, Pusa, New Delhi.

Subject: Renewal of Fire Safety Certificate in r/o Govt. Sarvodaya Kanya Vidhalaya, Located at Raj Nagar – 1, Palam Village, New Delhi .

Sir,

Please refer to letter no 54(SPS School)/PWD Edu. Sub- Divn M1-1 (N)/2021-22/8 Dated 28/02/2022 Email Dated - 29/04/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 09/05/2022 in the presence of Smt. Kaushalya Yadav.

During the course of inspection flowing shortcoming is observed.

1. Two stairs of 1.5 m clear width remotest to each other not provided at each floor in Block B.

However the terrace fire pump 450 LPM & ABC type fire extinguishers at each floor, terrace tank of 10,000 ltr capacity, Hose Reels at each floors are found provided in the premises.

You are requested to comply the abovementioned shortcoming under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atal Garg)
Director
Delhi Fire Service

Copy to:-

1. Directorate of Education Old Secretariat Delhi – 110054
2. The Principal, Govt. Sarvodaya Kanya Vidhalaya, Located at Raj Nagar – 1, Palam Village, New Delhi – 110045.(School Id 1824027)