

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2022/NDZ/ 1200

Dated: 27/05/2022

To

The Hyper Cafe (A unit of Blue Moon Cafe)
Nipun Tower, Plot No.15, Community Centre,
Karkardooma, Delhi-110092.

Sub.:- Fire Safety Certificate in r/o M/s Hyper Cafe, Nipun Tower, Plot No. 15, Community Centre Karkardooma, Delhi - 110092.

Sir,

With reference to your letter received through MHA portal application No. 2022040705881 Dated 04/01/2022 on the subject noted above, in this connection it is to inform you that the said building premises was inspected by the officers concerned of this department on 26/04/2022 in the presence of Sh. Parminder Chaudhary and observed that eating house is proposed on second floor in a building comprised of Basement, ground plus seven upper floors. Building is having valid FSC issued by this department vide letter no. 623 dated 16/12/2021.

Following shortcomings were observed during the time of inspection:-

1. 02 number of Staircases having width 1.10m & 0.94m are provided against requirement of 1.50 m width each.
2. 02 doors of width 2 m and 0.84 m are provided against requirement of 1.50 m width each.
3. Overhead tank 10,000 Ltrs. provided against requirement of 25,000 Ltrs.
4. Exit signages not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. you are requested to apply after rectification of above mentioned shortcomings under intimation to this department.

Yours faithfully,


(ATUL GARG)
Director

Copy to:-

1. Joint Commissioner of police (licensing), Defence Colony, New Delhi.
2. Deputy health officer, Shahdara Zone, New Delhi.