

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/School/2022/ 241

Dated 23/05/2022

To

The Manager  
J.C.Gaur Public School,  
Gali No. 5 to 8, Som Bazar Road,  
Mukund Pur, Part-II, Delhi-110042.

**Sub:** - Regarding issuance of fire safety certificate in r/o J.C. Gaur Public School, Gali No. 5 to 8, Som Bazar Road, Mukund Pur, Part-II, Delhi-110042.

Sir,

Please refer to your letter no. J.C.G.P.S/Fire/03/2022 dated 21.03.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 25.04.2022 to verify the fire safety arrangements provided therein as per the NBC Part 4. At the time of inspection Sh. Param Singh (Care Taker) was also present at site. As per earlier NOC issued vide letter of even no F6/MS/DFS/2006/2359 dated 07.09.2006 above said building was comprised of ground floor only. Now the school management has more floors on old building and constructed a new block having ground+03 upper floors. Both old and new block are interconnected with each other. The observations/ shortcomings noticed are as under:-

1. The approach road width is provided 04m against the requirement of 06m for movement of fire engine in case of emergency fires. And the entrance gate width of 3.50 provided against the requirement of 05m both.
2. The school building has three staircases 1.50m (interconnected new block & old block) ground to second floor & 01m (old block) from ground to terrace level. And third staircase is also provided is 1.50m (new block) from ground to third floor only needs to continuous from terrace level as NBC Part 4.
3. The width of class room doors is provided 85cm (old block) & 01m (new block) against the requirement of 1.20m.
4. There are total 10nos of fire extinguishers against the requirement of 14nos of ABC/CO2 fire extinguishers.
5. Hose reel hose provided but not functional and found some cracks in hose pipe and missing some nozzle.
6. MOEFA system not provided.
7. Terrace level fire pumps capacity 450lpm provided but not functional.
8. Overhead fire water tank capacity 6,000ltr provided against the requirement of 10,000ltr.
9. Exit signage's not provided at strategic location in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully

  
(Atul Garg)

Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 54.

J.C. Gaur