

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/School/SZ/2022/254

Dated: 27/05/2022

To

The Principal,  
New Bethal Christian School,  
A-394, Tigri Colony, New Delhi-62.

**Sub:-** Regarding renewal of Fire Safety Certificate in r/o **New Bethal Christian School located at A-394, Tigri Colony, New Delhi-62.**

Sir,

With reference to letter no. nil dated 22.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 03.05.2022 in the presence of Mrs. Rajni, Teacher and it was observed that the building is comprised of basement + ground + 03 upper floors. During the inspection following shortcomings were observed:-

1. Main and alternate staircase of 1.50 meters width each shall be provided in the building.
2. First aid hose reels not provided.
3. Fire pump having capacity 450 LPM not provided.
4. Terrace tank having total capacity of 10,000 liters shall be provided exclusively for fire fighting.
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Anil Garg)  
Director

Delhi Fire Service

etc  
24/5

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.