

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001

~~195806~~/DFS/MS/School/SZ/2022/ 260

Dated: 27/05/2022

To

The Principal (1st & 2nd Shift),
S.D.M.C Pratibha Vidyalaya,
Zakir Nagar-II (Urdu), Batla House,
Jamia Nagar, Central Zone, New Delhi-25.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **S.D.M.C Pratibha Vidyalaya located at Zakir Nagar-II (Urdu), Batla House, Jamia Nagar, Central Zone, New Delhi-25 [(School ID no. 1958059 (Girls) 1st shift & 1958060 (boys) 2nd shift].**


Sir,

With reference to letter no. nil dated 13.04.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 18.05.2022 in the presence of Mrs. Asma Qamar (Principal) and it was observed that the building is comprised of ground + 02 upper floors. During the inspection following shortcomings were observed:-

1. First-aid-hose reels found non function.
2. Fire pump found non functional.
3. Terrace tank having total capacity of 10,000 liters shall be provided exclusively for fire fighting.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.