

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/ 257

Dated: - 27/05/2022

To.

The Principal,
Shri Sanatan Dharam Girls Sr. Sec. School,
East Patel Nagar, New Delhi- 110008.

Sub.-: Regarding renewal of Fire Safety Certificate in r/o Shri Sanatan Dharam Girls Sr. Sec. School, East Patel Nagar, New Delhi- 110008.

Sir,

With reference to your online email Id vdsfirefighting@gmail.com dated 24.04.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 09.05.2022 in presence of Smt. Rekha Verma, Principal of the school, to check the fire safety arrangements provided in the school building.

During the inspection, it was also observed that the said school having three blocks namely 1, 2 & 3 are Inter-Connected with each other, 1st & 3rd block are comprised of ground plus one upper floor and 2nd block is comprised of ground plus two upper floors. Fire safety arrangement such as fire extinguishers, First-Aid hose reels etc. found provided. However following shortcomings were observed: -

1. Access to terrace pump and overhead water tank is not provided for inspection.
2. Continuous staircases up to terrace found not provided.

In view of the above, 'Fire Safety Certificate' cannot be granted at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Atul Gang) [Signature]
Director
Delhi Fire Service

Copy to: -

The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi- 110054 .

For information please.