

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/2022/SZ/266
To,


Dated: 27/05/2022

The Manager,
KMI School, Q1-2,
Mohan Garden, Uttam Nagar,
New Delhi-110059.

Sub: Regarding renewal/issuance of Fire Safety Certificate in respect of KMI School, Q1-2,
Mohan Garden, Uttam Nagar, New Delhi-110059.
Sir,

This has reference to your letter no. Nil dated 20/04/2022 on the subject captioned above. In this connection, it is to inform you that the above mentioned building/premises was inspected by the officer concerned of this department on 12/05/2022 in the presence of Mr. Malhotra (Manager) to verify the compliance of shortcomings already communicated by this department vide letter no. F6/DFS/MS/School/2020/SZ/607 dated 01/09/2020 and observed that shortcomings are still not rectified. The management will be held responsible for any untoward incident for the period if compliance is not made.

Yours Faithfully,



(SUNIL CHAUDHARY)
DY.CHIEF FIRE OFFICER
DELHI FIRE SERVICE



Copy to:-

1. The Executive Engineer (Bldg.), HQ-II, SDMC, 8th Floor, Dr. S.P.M Civic Centre, E-Wing, J.L. Nehru Marg, New Delhi-110002
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.
(with a request to take further action as school does not have FSC)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No: F.6/DFS/MS/School/2020/SZ/ 607
To,

Dated: 01/09/2020

The Manager,
KMI School, Q 1-2,
Mohan Garden, Uttam Nagar, New Delhi-110059
brchaba61@gmail.com


Sub: Regarding issuance of NOC/Fire Safety Certificate in respect of KMI School, Q 1-2, Mohan Garden, Uttam Nagar, New Delhi-110059

Sir,

This is in reference to your email letter dated 14.08.2020 received from brchaba61@gmail.com on the subject cited above. In this regard it is to inform you that to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS Rules-2010 on the said premise/building two sets of sanctioned building plan/as built plan with section/elevation along with usage of each floor on the scale of 1:100 duly marked with fire and life safety system forwarded through building/local authority are required. In addition to this Documentary proof for year of construction is also required.

Thus you are requested to provide the information/documents pertaining to this building as mentioned above and apply in Form "I" for taking further action as necessary for grant of Fire Safety Certificate.

Yours Faithfully,


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Executive Engineer (Bldg.), HQ-II, SDMC, 8th Floor, Dr. S.P.M Civic Centre, E-Wing, J.L. Nehru Marg, New Delhi-110002
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054. (with a request to take further action as school does not have FSC)