

468

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI 110001

No. F.6/DFS/MS/GH/SZ/2022/ 381

Dated: 23/05/2022

To

Sh. Sumit Anand (Owner/Occupier),
Ananda guest house, 8/41, WEA,
Abdul Aziz Road, Karol Bagh, New Delhi- 110005.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Ananda guest house located at 12/19, WEA, Abdul Aziz Road, Karol Bagh, New Delhi- 110005.

Sir,


Please refer to your Online Application No. 2022041607250 dated 18.04.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 09.05.2022 in the presence of Sh. Sumit Anand (Owner), to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus three upper floors. Guest house served by 01 staircases having width 1.25 mts from ground to terrace floor and 01 staircase having width 1.24 to 1.37 mts. from basement to ground floor. Fire safety arrangements such as first aid hose reel, fire extinguishers, D.G.Set etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. Fire Check door found not provided.

In view of the above shortcoming 'Fire Safety Certificate' cannot be renewal at this stage. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to :-

The Joint. Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor,
New Delhi- 110049.