


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2022/ *college/21*

Dated: *26* /05 / 2022

To

Sh. Ravinder Nigam
Section Officer,
District Institute of Education and Training,
Institutional Area, Karkardooma,
Delhi-110092.

Subject: Application for grant of Fire Safety Certificate in r/o District Institute of Education and Training, Institutional Area, Karkardooma, Delhi-110092.

Sir,

Please refer your letter F. No. 2(2)/DIET/KKD/Buildg./03/1142 dated 09/05/2022, on the subject cited above. In this connection it is submitted that this department has already communicated the observations vide letter No. F.6/DFS/MS/BP/2020/441 dated 11/02/2020 (copy enclosed). Therefore, you are requested to abide by the same.

Yours faithfully,


(ANIL GARG)

DIRECTOR

Ph. 011-23414000

01/03/2022

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI - 110001.

NO. F.6/ DFS /MS/BP/2020/ 441

Dated 11/02/2020

To.

Sh Ravinder Nigam
Section Officer
DIET, Institutional Area, Karkardooma
Delhi

Sub:- Regarding issue of NOC in r/o DIET, at Institutional area Karkardooma,
Delhi -92.

Sir

Please refer to your letter NO. F.No. 2(2)diet/kkd/BUILDG./03/256 DATED 22.01.2020 on the subject cited above. In this connection, it is to inform you that the above referred building plans have been scrutinized by this department from fire & life safety point of view and observed that there is a professional training institute building comprising of basement, ground and three upper floor at, Karkardooma Shahdara, Delhi.. The height of building is 13.20 meter. During the scrutiny following shortcomings are observed.

1. The plot area and all floors area including basement is not provided on the plans as per UBBL-2016.
2. Alternate staircase of 1.5 meter is not proposed as per clause 7.10 of UBBL-2016.
3. Fire fighting arrangements such as over head tank, pump, etc as per NBC -IV are not proposed on the plans.

Therefore, you are requested to rectify to above shortcomings and re submit for further consideration in the matter.

Yours faithfully


(Virendra Singh)

Dy. Chief Fire Officer

011 - 23412025

