

442

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI

No.F6/DFS/MS/SZ/2022/ College/19

Dated: 21/05/2022

To,

The Authorized Signatory,
Bhaskaracharya College of applied Sciences
(University of Delhi).

Subject: Mock Drill for safety from Fire Disaster in Bhaskaracharya College of applied Sciences (University of Delhi).

Sir,

Please refer to Letter no BCAS/4(3)/2022/125 dated 20/04/2022 on the subject mentioned above In this connection it is to inform you that the Fire Safety Certificate issued to you vide letter no F6/MS/DFS/2003/392 dated 21/02/2003 has already expired and not renewed till now. However certain shortcoming has also communicated to you vide letter no F6/DFS/MS/2016/South/395 dated 11/02/2016 but till date no compliance is received to this department.

In view of above you are advised to comply the shortcomings communicated vide above letter and get renew the FSC at the earliest.

The premises shall be at the risk of owner / occupier until the FSC is renewed by this department.

Yours faithfully,


(Atul Gang)
Director

Delhi Fire Service

Copy to: -

1. The Secretary (Higher Education), GNCTD, The Complex, Muni Maya Ram Marg, Pitampura, Delhi – 110034 <pstechedu@nic.in>
2. The Directorate of Higher Education, GNCTD, The Complex, Muni Maya Ram Marg, Pitampura, Delhi – 110034.<dltehedu@gmail.com>
3. The Registrar, University of Delhi, Delhi – 110077 <registrar@du.ac.in>
4. The Executive Engineer (E), PWD EMD South West (M-152), GNCTD J.B.Tito Marg, Andrew Ganj, New Delhi – 110049 <eeepwddelhim152@gmail.com>

C-52

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/2016/South /395

Dated: 11/02/16

To,

The Principal,

Bhaskaracharya College of Applied Sciences,

(University Of Delhi),

Sector-2, Dwarka, Dwarka, New Delhi-110075.

Subject: - Fire Safety Certificate in r/o Bhaskaracharya College of Applied Sciences,
(University Of Delhi), Sector-2, Dwarka, Dwarka, New Delhi-110075.

Sir,


This is in reference to your letter no. BCAS/17(1) Elec./2016/2289 dated 13.1.2016 on the subject cited above. In this connection it is to inform you that the above said Institutional building have been inspected by the officers concerned of this department from fire safety point of view on 27.1.2016 in your presence.

During the course of inspection the following points have been observed:-

1. First Aid Hose Reels: provided, but some of the hose reels not found functional.
3. Pumping Arrangements: 2 Nos. Terrace pump of 900 LPM provided, but one of them not found functional.

In view of the above shortcomings renewal of fire safety Certificate cannot be considered at this stage. You are advised to rectify the above said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Atul Garg)

o/c
Dy.Chief Fire Officer
Ph.011-26189168

