

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2021/376

Dated: 23/05/2022

To

The Joint. Commissioner of Police (Lic.),  
Police Station, Defence Colony, 1st floor,  
New Delhi- 110049.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Hotel Sushanta Nikatan located at 6753, Gali No. 2, Block 10, Dev Nagar, Karol Bagh, New Delhi- 110005.

Sir,


Please refer to your Online Application No. 2021062614280 dated 29.06.2021, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 13.07.2021 in the presence of Sh. Omi Singh (Manager), to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus four upper floors served by single staircases having width 0.98 mts from basement to ground floor and 0.92 mts. from ground to terrace floor. Fire safety arrangements such as overhead water tank capacity 5000 lts, terrace pump, first aid hose reel, MOEFA, sprinkler system in basement floor, fire extinguishers, D.G.Set etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 and letter No. F.5(189)/AD/LB/2016/359-374 dated 29.06.2021 in respect of existing building (copy enclosed) shall be implemented by 30.09.2021 in respect of existing building :-

1. Electric fire pump not in working condition.
2. Emergency light found removed.
3. MOEFA found provided but not functional.
4. P.A system found provided but not functional.

In view of the above shortcomings, renewal of the 'Fire Safety Certificate' cannot be considered at this stage. You are advised to rectify the above mentioned shortcomings under intimation to this department for further necessary action in this matter and running of guest house in absence of fire safety certificate will be at the owner's risk and responsibility.

Yours faithfully



(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to :-

The Owner, M/s. Hotel Sushanta Nikatan located at 6753, Gali No. 2, Block 10, Dev Nagar, Karol Bagh, New Delhi- 110005.