

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No.F6/DFS/MS/School/SZ/2022/ 247

Dated: 25/05/2022

To

The Principal,  
Modern Public School,  
GD-6, Pul Prahlad Pur, New Delhi-44.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of **Modern Public School located at GD-6, Pul Prahlad Pur, New Delhi-44.**

Sir,

With reference to your letter no. MPS/2022 dated 21.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 11.05.2022 in the presence of Mrs. Geeta Sharma (HOS) and it was observed that the building which was earlier comprised of basement & ground floor only is now comprised of basement & ground + 01 upper floors & school is running on basement & ground + 01 upper floors. There is change of occupancy at basement & 1<sup>st</sup> floor has been newly added to the building. Hence is a case addition/alteration. The fire and life safety requirements are therefore applicable as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. School is not accessible to fire engine as approach road width is less than 6.0 meters
2. Main and alternate staircase of 1.50 meters width each shall be provided in the building.
3. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Abu) Garg

Director

Delhi Fire Service

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.