

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/School/2022/NDZ/ 268

Dated: 30/05/2022

To,

The Principal
National Victor Public School,
Gali No. 02, Brahampuri, Delhi-110053

Subject: -Regarding issuance of Fire Safety Certificate in r/o National Victor Public School located at Gali No. 02, Brahampuri, Delhi-110053.

Sir,

With reference to your letter No. NVPS/21-22/010 dated 31/03/2022 on the subject cited above. It is to informed, school premises was visited by officer concerned of this department on dated 28/04/2022 and observed that building now comprised of ground plus three upper floor plus 12 rooms on terrace, however Fire Safety Certificate is issued to your school by this department vide letter No. F6/DFS/MS/School/2016/NDZ/910 dated 01/06/2016 for ground plus three upper floors only. As 12 rooms are constructed on terrace which is clear case of addition/alteration.

Accordingly, it is requested to forward complete set of building plans including in UBBL-2016 duly marked with fire and life safety systems as per NBC Part-IV through online system of concerned building sanctioning authority to assess the fire and life safety requirement for issuance of fire safety guidelines/directives.

Yours faithfully



(Atul Garg)
Director

Delhi Fire Service

Copy to:-

Director of Education,
B Block Yamuna Vihar
Delhi-110053

etc 2