

426

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/NDZ | 378

Dated 23.05/2022

To,

The Manager,
Hotel Nitya Maharani Guest House,
7884/1, Plot no. 27, A.K, Road,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o Nitya Maharani Guest House, 7884/1, Plot no. 27, A.K, Road, Pahar Ganj, New Delhi. ID No. 2021100123041 dated 01.10.2021.

Sir,

This has reference to your ID No. 2021100123041 dated 01.10.2021, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned department on 05/05/2022 in the presence of **Manager** and the following shortcomings were observed:-

1. Smoke Management System are not provided as per gazette notification dated 27.05.2019
2. CO type detectors are not provided as per gazette notification dated 27.05.2019.
3. Fire Check door are not provided as per gazette notification dated 27.05.2019.
4. Building Plan as uploaded is not signed by architect & owner.

In view of above, the Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.