

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/GH/NDZ/2022/ 373

Dated: 19/05/2022

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

**Sub:** Regarding renewal of Fire Safety Certificate in respect of **M/s Salam Guest House** located at **899, Chattu Sheikh Mangloo, Jama Masjid, Delhi.**

Sir,

With reference to online application I.D. no. 2022040906364 dated 09.04.2022 on the subject cited above, it is informed that the guest house was inspected by Assistant Divisional Officer (SPM) from this department on 26.04.2022 in the presence Mr. Nihal Ahmad (Manager) and it was observed that building is comprised of Basement + Ground + 03 upper floors + Terrace floor. During inspection, following shortcomings were observed:

1. Fire check door in basement (storage) not provided.
2. Kitchen on terrace floor not allowed as per gazette notification dated 27.05.2019.
3. First Aid Hose reels found non functional.
4. Fire extinguishers not adequately provided.
5. Plans for all floors not found attached with application: You are requested to forward the plan with section & elevation.
6. Occupancy above third floor is not permitted as per gazette notification dated 27.05.2019

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
18/5/22

**(Dr. S.K. Tomar)**

Dy. Chief Fire Officer

Tel: 011-23412025

**Copy to:-**

The Manager,

M/s Salam Guest House at 899, Chattu Sheikh Mangloo, Jama Masjid, Delhi.