

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

No.F.6/DFS/MS/SZ/2022/ 248

Dated: 25/05/2022

To,

Smt. Kiran Bala Sharma (Principal) <mcpsdwarkasector7new@gmail.com>
S.D.M.C Primary School,
Sector - 7, Dwarka,
New Delhi - 110045.

Subject: Renewal of Fire Safety Certificate in r/o S.D.M.C Primary School (ID - 1757211) Located at Sector - 7, Dwarka, New Delhi - 110045.

Sir,

Please refer to your Email dated 25/04/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officer concerned from this department on 06/05/2022 for fire safety point of view in the presence of Smt. Kiran Bala Sharma (Principal).

The following shortcoming was observed during the time of inspection:-

1. Only 5 ABC type fire extinguishers are provided against required 10 ABC type fire extinguishers.
2. Hose reel hoses found nonfunctional.
3. Terrace pump found nonfunctional .
4. Over head water tank of 10,000 ltr capacity found empty.
5. Exit Signage found removed at some places.

You are requested to comply the above mentioned shortcomings under intimation to this department for further necessary action.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service.

Copy to; - Directorate of Education Old Secretariat Delhi - 110054