

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

440

No. F6/DFS/MS/EH/WZ/2022/ 351

Dated: 23/05/2022

To,

The Joint Commissioner of Police (Lic),  
1<sup>st</sup> Floor, Licensing Unit,  
Police Station, Defence Colony,  
New Delhi. ([adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in))

**Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Veranah Moon Shine (Viaban Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi-110026.**

Sir,

Please refer to your online application no. 2022041206793 dated 12/04/2022 on the subject mentioned above. In this connection it is to inform you that the premises was inspected by the officers concerned of this department on 23/04/2022 in the presence of Sh. Ashwani (Manager) to check the Shortcomings already issued by this deptt. Vide Letter No.F6/DFS/MS/WZ/2020/49 dated 09/01/2020, F6/DFS/MS/WZ/2020/317 dated 19.03.2020, F6/DFS/MS/MN/2021/242 dated 24/05/2021.

During course of inspection, it was observed that the restaurant is running at Third Floor in a Building comprised of Basement, Stilt, Ground plus three upper floors only. However, the statuses of shortcomings are as under.

S.N.	Shortcomings	Status
1.	Two Exits of 2m & 1.5 m each clear width remotest to each other are not provided.	Provided 2 mtr width of iron made staircase, but Stability certificate is required from registered engineer.
2.	Two Stairs of 2 m & 1.5 m each clear width remotest to each other are not provided.	Rectified
3.	Hose Reel Hose of 30 mts length is not provided.	Not Rectified
4.	Hydrant with hose box is not provided.	Not Rectified
5.	Automatic Fire Alarm System is not Provided.	Provided but not working
6.	Main & stand by pumps of 2280 lpm are not provided.	Not Rectified
7.	Terrace Fire Pump of 450 lpm with 40m head is not provided.	Provided but not working
8.	Under Ground Fire Water Tank of 100000 ltrs is not provided	Not Rectified
9.	Overhead water tank of 10000 ltrs capacity not provided.	Rectified
10.	Jockey pump of 180 LPM found not provided.	Provided but not working
11.	Exit signage's not provided.	Not Rectified

In addition to the above, the use of terrace floor as restaurant shall not be run without the permission of concerned local authority.



In view of above shortcomings, issuance of fire safety certificate is rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
Anil Garg  
Director  
Delhi Fire service

Copy to: -

1. M/s Verandah by Moon Shine (Vaiban Hospitality Pvt. Ltd.) Located at Plot no-02, 3<sup>rd</sup> Floor, Road No-85, West Punjabi Bagh New Delhi-110026.
2. Dy. Health Officer, West Zone, Shivaji Enclave Rajouri Garden New Delhi-110027. ([dhwest\\_zone@gmail.com](mailto:dhwest_zone@gmail.com)). — for taking in action

  
12/5  
  
12/5/22