

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

NO. F.6/DFS/MS/School/2022/NDZ/270

Dated: 30/05/2022

To.

The Principal,
Victor Public School,
Main Chowk, Maujpur,
Delhi-110053

Subject:- Regarding Renewal of Fire Certificate in r/o Victor Public School located at Main Chowk, Maujpur, Delhi-110053.

Sir.

With reference to your letter No. VPS/2022/2223 dated 31/03/2022 on the subject cited above, it is informed that, the officer concerned of this department has carried out the inspection of the above mentioned premises from fire safety point of view in presence of Sh. Deepak (Accountant) and observed that the school building is comprised of ground plus three upper floors and 3rd floor have been erected without approval of this department. Earlier NOC was issued for the ground plus two upper floors only. This is clear case of addition/alteration. The following information/documents pertaining to the premises/building are required:-

1. Sanctioned/Completion plans on the scale of 1:100 having details of height/covered area, year of construction/conversion of occupancy duly marked with fire and life safety arrangements as stipulated under Rule 33 of Delhi Fire Service Act of Rules 2010.

In view to the above, the premises can not be considered for issuance of renewal Fire Safety Certificate at his stage. Therefore, you are requested to provide above mentioned information/documents at the earliest for further consideration.

Yours Faithfully,


(Anil Garg)
Director

Delhi Fire Service

o/c