

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No. F6/DFS/MS/School/2022/SZ/ 267

Dated: 30/05/2022

To,

The Manager,  
Vikas Valley Public School,  
S-11,12,13-S-Block, Vikas Nagar,Hastal, New Delhi.

**Sub:** - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o Vikas Valley Public School,S-11,12,13-S-Block, Vikas Nagar,Hastal, New Delhi.

Sir,

Please refer to your letter no. VVPS/04/2022 Dated- 07/04/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school building on 17/05/2022 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh Sumil Arora (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. One staircase shall be provided of 1.5 m wide.
2. An additional hose reel shall be provided.
3. Fire pump having 450 lpm provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

**Director**

Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054. (with a request to take further action as school does not have fire NOC)