

C 79

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/44/371

Dated 19/05/2022

To,

The Manager,
K87 Orchid Garden 51/1,
Prabhat Road, D.B.G. Road,
Karol Bagh, New Delhi.

Sub: Regarding renewal of FSC in r/o K87 Orchid Garden at 51/1, Prabhat Road, D.B.G. Road, Karol Bagh, New Delhi ID No. 2022033104771 dated 31.03.2022.


Sir,

This has reference to your ID No. 2022033104771 dated 31.03.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned department on 10/05/2022 in the presence of **Manager** and the following shortcomings were observed:-

1. Fire Check doors are not provided as per gazette notification dated 27.05.2019.
2. CO type detectors are not provided as per gazette notification dated 27.05.2019.
3. Further, Affidavit not to use any floor above third floor also not submitted by owner.

In view of above, the Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


17/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.