

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

**NEW DELHI**

Dated: 23/05/2022

No. F6/DFS/MS/WZ/EH/2022/ 344

To,  
The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
addlep.lic-dl@nic.in

Sub: - **Inspection report in r/o Lord of Drinks ( A unit of RV café Pvt. Ltd.) located at Second floor, A-13, Ground floor, First floor, Najafgarh Road, Rajouri Garden, New Delhi-110027.**

Sir,

Please refer to your online application no.:- 2021021110329 dated 07/04/2022 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officers concerned of this department on 04/05/2022 in the presence of Mr. Deepak (Manager) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the restaurant is running at ground, 1<sup>st</sup> & 2<sup>nd</sup> floors in a building comprised of Basement + Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, First Aid hose reels, Internal Hydrant & Terrace Pump etc provided. However the following shortcomings were observed.

1. Fire Check Door in staircases found removed.
2. First Aid hose reels are provided but not functional.
3. MOEFA is provided but not functional.
4. P.A. system is provided but not functional.
5. Internal Hydrant is provided but not functional.
6. Terrace Fire Pump of 450 lpm & Jockey pump 180 lpm are provided but not functional.
7. Over head water storage tank capacity of 5,000 ltrs is provided against requirement of 10,000 ltrs.
8. Exit signages are found removed.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy to: -

1. The Owner/ Occupier M/s Lord of Drinks ( A unit of RV café Pvt. Ltd.) located at Second floor, A-13, Ground floor, First floor, Najafgarh Road, Rajouri Garden, New Delhi-110027. **Online application ID no.:- 2021021110329 dated 07/04/2022**
1. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.  
Email Id : - (dhowest [zone@gmail.com](mailto:zone@gmail.com)).

461

20/5/2022