

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2022/366

Dated: 30/05/2022

To

The Joint Commissioner of Police (Lic.),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub.-: Inspection report for issuance of Fire Safety Certificate in r/o M/s. SOW Café (a unit of Buildhigh Enterprises Pvt. Ltd.) located at UGF-1-3, Gold Souk Mall, Pitampura, New Delhi- 110034.

Sir,


Please refer to the online application No. 2022040906294 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant has been inspected by the officer concerned of this department, in presence of Sh. Rohit Grover (owner) on 11.05.2022 to check the fire safety arrangements provided in the premises.

During inspection, it has been observed that the said restaurant is running on first floor of a building comprised of basement, ground plus three upper floors. No fire safety arrangement found provided except few fire extinguishers. The following fire safety arrangements are required: -

1. All exits are provided on the same side.
2. Overhead water storage tank capacity 20,000 lts is required.
3. Terrace pump capacity 450 LPM is required.
4. MOEFA at each floor is required.
5. Down comer system is not provided.
6. First aid hose reel hose having 30 mts length with shut off nozzle & down comer with two nos. of delivery hoses and one branch pipe are required at each floor.
7. Exit signages are required at the places mentioned during inspection.
8. Standby power supply is required.

In view of the above shortcomings, the application for grant of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite Fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours faithfully


(M. G. G.)
Director

Copy to: -

1. The Deputy Health Officer, North Delhi Municipal Corporation, Keshavpuram Zone, New Delhi.
2. Sh. Rohit Grover, M/s. SOW Café, UGF-1-3, Gold Souk Mall, Pitampura, New Delhi- 110034.