

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F6/DFS/MS/EH/SZ/2022/369

Dated: 30/05/2022

To

Sh. Anil Kumar (Owner/Occupier)
M/s. Jubilant Foodworks Ltd. (Dominos Pizza),
S.NO. 2A,2B,2C,2D,2E & 2F, Plot no. 1/1,GF,
East Patel Nagar Metro Station, Patel Nagar, New Delhi-110008

Sub.:- Regarding issuance of Fire Safety Certificate in respect of M/s. Jubilant Foodworks Ltd. (Dominos Pizza), located at Plot No.1/1,GF, S.NO. 2A,2B,2C,2D,2E & 2F, East Patel Nagar Metro Station, Patel Nagar, New Delhi -110008,

Sir,

Please refer to your online application No. 2022050909751 dated 09.05.2022 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the aforesaid restaurant/eating house running at ground floor of building comprised of basement, ground plus three upper floors has been inspected by the officers concerned of this department, in presence of Sh. Sandeep (manager) on 23.05.2022 to check the status of the shortcomings already pointed out by this department vide letter No. F6/DFS/MS/EH/SZ/2022/164 dated 04.02.2022. During the course of inspection, it was observed that the shortcomings are not complied.

In view of above, Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further necessary action in this matter and running of a restaurant in absence of fire safety certificate is not safe. Any loss of life and property will entirely be sole responsibility of the owner/occupier.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.

e-10

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No F6/DFS/MS/EH/SZ/2022/ 164

Dated: 04/02/2022

To,

Sh. Naveen Gupta,
Jubilant Food works Ltd. (Domino's Pizza),
S. No. 2A, 2B, 2C, 2D, 2E & 2F, Plot No.- 1/1, GF,
East Patel Nagar Metro Station, Patel Nagar, New Delhi- 110008.

Subject: - Regarding grant of Fire Safety certificate r/o Jubilant Food works Ltd. (Domino's Pizza), S. No. 2A, 2B, 2C, 2D, 2E & 2F, Plot No.- 1/1, GF, East Patel Nagar Metro Station, Patel Nagar, New Delhi- 110008.

Sir,

This has reference to your Online Application ID 2022011200665 dated 13.01.2022 on the subject cited above. Above said restaurants running at ground floor of a building comprised of basement, ground plus three upper floors. In this connection it is to inform you that the above said assembly building (Restaurant) was inspected by the officer concerned of this department from safety point of view on 24.01.2022 in presence of Mrs. Manju (Shift Manager).

During the course of inspection it has been observed that fire safety arrangements such as fire extinguishers, MOEFA, smoke detector etc. found provided. Wide the following shortcomings have been observed:-

1. Width of main door & alternate door provided 1.80 mts & 0.92 against requirement width of 2.0 & 1.50 mts.
2. First aid hose reel found not provided.
3. Internal hydrant system found not provided.
4. Terrace pump capacity 450 LPM is found not provided.
5. Overhead water Tank required capacity 20,000 Its found not provided.
6. Exit signages are not provided at the places mentioned during the inspection.

In view of the above shortcomings fire safety certificate cannot be considered at this stage. You are advised to rectify the above mention shortcomings and apply fresh for taking further necessary action.

Yours faithfully,


(Atul Garg)
Director

Copy to:-