

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE NEW DELHI-110001**

No. F6/DFS/MS/School/2022/NDZ/286

Dated: 03/06/2022

To,

The Principal,
EDMC Primary School,
B-2, Nand Nagri,
Delhi-110094.

Subject: -Regarding issuance of Fire Safety Certificate in r/o EDMC Primary School B-2, Nand Nagri Delhi-110094.

Sir,

Please refer to letter. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this regard, it is to inform you that, the inspection of the above said premises was carried out by the officer concerned of this department in presence of Mrs. Shahiba Parveen,(Incharge) on dated 25/05/2022. During the inspection it was observed that the shortcomings as communicated earlier vide letter No. F6/DFS/MS/School/2022/NDZ/23 dated 20/01/2022 are yet to be rectified. Copy of the same is enclosed for your ready reference.

In view of the above Fire safety Certificate cannot be considered at this stage, you are once again requested to rectify the said shortcoming under intimation to this office for further consideration in the matter.

Yours faithfully



(Dr. S.K Tomar)
Dy.Chief Fire Officer



Copy to:-

- 1) The Director of Education,
Udyog Sadan, Plot No.419, FIE,
Patparganj Industrial Area, Delhi-110092
- 2) The Ex. Eng. (Elect,-)II,
Shahdara (North)Zone,
EDMC, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.

C 38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZ/ 23

Dated 20/01/2022

To,
The Manager,
EDMC Primary School
B-2, Nand Nagri,
Delhi-110094

Sub:- Regarding Issuance Fire Safety Certificate in EDMC Primary School B-2, Nand Nagri
Delhi-110094.

Sir,

With reference to your letter No. nil dated 27/12/2021 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 05/01/22 in presence of Mrs Shahiba Parveen, Principal of the School. The following points / shortcomings were noticed in the building comprised of ground plus three upper floors (two separate blocks).

1. Over head tank 3,000 ltrs provided in place of 10,000 liter in as required.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92