

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/MS/School/2022/NDZ/287

Dated 03/06/2022

To,

The Principal,
EDMC Primary School,
Sunder Nagri, F-1-1st,
Shahdara, Delhi-110093

Sub:- Regarding Issuance Fire Safety Certificate in r/o EDMC Primary School at Sunder Nagri, F-1-1st,
shahdara, Delhi-110093.

Sir,

With reference to your letter No. EDMC/EE(E)-I/SHN/2021-22/D-40 dated-02/05/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned school from fire safety point of view on dated 25/05/22 in presence of Mrs. Rajbala Principal. The following points / shortcomings were noticed in the building comprised of ground plus two upper floors .

1. Fire Extinguisher not functional.
2. First Aid Hose Reels not functional.
3. A fire pump having 450 LPM output at 40 meters head not functional.

In view of above, the building can not be considered for issuance of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)
Director

o/c [Signature]

Copy to:-

1. The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi 92
2. The Ex. Eng. (Elect.)-II,
Shahdara (North)Zone,
EDMC, Office of Executive Engineer (Elect)-II,
MCD Zonal Office Buildings, Keshav Chowk,
G.T. Road, Near Shyam Lal College.