

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/School/SZ/2022/278

Dated: 03/06/2022

To

The Principal,
Jai Bharti Convent School,
Lane no. 11, Molarband Extn.,
Badarpur, New Delhi-44.

Sub:- Regarding renewal of Fire Safety Certificate in r/o **Jai Bharti Convent School located at Lane no. 11, Molarband Extn., Badarpur, New Delhi-44.**


Sir,

With reference to your letter no. nil dated 31.03.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 24.05.2022 in the presence of Mr. Nandlal Yadav (Manager) and it was observed that the building is comprised of ground + 01 upper floors. During the inspection following shortcomings were observed:-

1. Fire extinguisher found removed.
2. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.

o/l
01/6