

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001**

No. F6/DFS/MS/School/2022/SZ/ 275

Dated: 03/06/2022

To,

The Principal,
Rao Bal Ram Public School,
Gopal Nagar, Najafgarh, New Delhi-43.

Sub:-Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Rao Bal Ram Public School, Gopal Nagar, Najafgarh, New Delhi-43.


Sir,

Please refer to your letter Nil Dated 10/05/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Mr. Rahul (Admin.) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings:-

1. Fire extinguishers are provided but not functional.
2. First Aid Hose reels provided but not functional.
3. Fire pump having 450 LPM output at 40 m head provided but not functional.
4. Exit signage's are found missing.

Keeping in view of above, the building cannot be considered for issuance of fire safety certificate, at this stage. Therefore you are advised to rectify the above said shortcomings under the intimation to this department for further course of action.

Yours faithfully


(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi-110054.

(With a request to take further action as school does not have fire NOC)