

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/284

Dated: 03/06/2022

To,

The Principal,
St. Angel's School,
(Senior Secondary), A-Block, Sector-15,
Rohini, Delhi-85.

Sub: Issue of FSC in r/o St. Angel's School, (Senior Secondary), A-Block, Sector-15, Rohini, Delhi-85.

Sir,

Kindly reference to online e-mail dated 03.03.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **17.05.2022**, in presence of **Mr. Archit Bhardwaj** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. Hose reel not provided in basement.
2. Terrace pump of 900 lpm is provided but not functional
3. The required exit signage is not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ht
tp://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

01
24