

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/2022/SZ/ 1220

Dated: 03/06/2022

To,

Sh. T.N. Singh (Manager),  
Room No-206, 2<sup>nd</sup> floor, Vishva Sadan Building,  
Plot No.-09, District Centre, Janak Puri, New Delhi-58.

**Sub:** - Non-Compliance of Fire Safety Norms in r/o Vishva Sadan Building, Plot No.-09, District Centre, Janak Puri, New Delhi-110058

Sir,

Please refer to your letter no. F.1/DD (Bldg) C&I/2022/50 dated 13/04/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on 19/05/2022 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. T.N.Singh (Manager) was present and it was observed that the building is comprised of Basement, ground floor, upper ground floor & eight upper floors and have following shortcomings.

1. Fire Check doors are found removed at some places.
2. Smoke management system provided but not functional in basement.
3. First aid hose reels are provided but not functional.
4. MOEFA & Automatic fire detection system provided but not functional.
5. Automatic sprinkler system provided but not functional in basement.
6. Internal & Yard hydrant provided but not functional.
7. Fire pumps are not functional.
8. Illuminated exit signages are not provided.

Keeping in view of above you are hereby directed to remove the above said shortcomings within a period of **thirty days** from issuance of this letter under intimation to this department, otherwise action will be initiated against the said premises as per Delhi Fire service Act 2007, Rules 2010. Further it is also to clarify that the present occupancy of the building premises is on the risk and responsibility of the owner/occupiers.

Yours faithfully

  
(Atul Garg)  
Director

Delhi Fire Service

Copy to:-

1. The Director (Building), DDA, Vikas Sadan, INA, New Delhi