

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/285

Dated: 03/06/2022

To,

The Principal,  
D. V. Public School,  
F-205, Phase-I, Vijay Vihar,  
Rohini, Delhi-85

**Sub:** Issue of FSC in r/o D. V. Public School, F-205, Phase-I, Vijay Vihar, Rohini, Delhi-85.

Sir,

This is in reference to your letter No. D.V.P.S/2022/1013 dated 04.01.2022 received through outdoor diary no. 6713 dated 21.02.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **18.05.2022**, in presence of **Mr. Durgesh (Admin)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 5000 liters over head water capacity tank provided against the required capacity of 10,000 liters & found empty.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:  
[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dhrampal Bhardwaj)  
Dy. Chief Fire Officer  
Tel;-01123414250

etc  
04