

194) 1920/1032

0/4

C 43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

Date: 30/05/2022

No. F.6/DFS/MS/GH/2022/WZ/399

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addep.lic-dl@nic.in

Sub:- Inspection report in respect of M/s. Aman Deluxe, A- 30, Vishal Enclave, Rajouri Garden, New Delhi- 110027.

Sir,


Please refer to your Online Application ID. No. 2022042107786 dated 21/04/2022 on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 13/05/2022 in the presence of Sh. Aman to check the Fire safety arrangements.

During inspection, It was observed that the building is comprised of Basement + Ground + 03 Upper Floors, Guest House is running at Ground floor (Reception) + 1st Floor (06 rooms) + 2nd floor (06 rooms) & 3rd floor (06 rooms). Fire safety arrangements such as Smoke Management System, Fire Extinguishers, First-Aid Hose Reel, MOEFA, Internal Hydrant, Pumping Arrangement, Overhead Tank, and Exit Signage etc. However, following shortcomings were observed:-

1. Fire Check Door Found removed in Basement.
2. First Aid Hose reels are provided but not working.
3. Carbon Monoxide (CO) detector is not provided.
4. Location of Main Panel at Ground Floor is not provided.
5. Hooters Location at all floors are not provided.
6. MOEFA is provided but not working.
7. Automatic sprinkler system is provided in Basement but not Functional.
8. Terrace pump of 450 LPM & 180 LPM is provided but not functional & not on auto mode.
9. Overhead water storage tank 2000 ltr provided against requirement of 5000ltr.
10. Exit signage's are found removed.


In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. Sh. Aman, M/s Aman Deluxe, A-30, Vishal, Enclave, Rajouri Garden, New Delhi- 110026.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027.


25/07/2022