

145/1000/1000
21372
C 74

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001

No. F.6/DFS/MS/GH/2022/WZ/ 400

Dated 30/05/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addelep.lic-dl@nic.in

Sub:- Inspection report in respect of M/s. Aman Palace, A- 40, Vishal Enclave, Rajouri Garden, New Delhi- 110027.

Sir,


Please refer to your Online Application ID. No. 2022042107857 dated 21/04/2022 on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on 11/05/2022 in the presence of Sh. Amandeep mahindru to check the Fire safety arrangements.

During inspection, it was observed that the building is comprised of Basement + Ground + 03 Upper Floors (Basement floor is used as storage), Guest House is running at Ground floor (Reception) + 1st Floor (05 Rooms & 01 Office), 2nd floor (06 Rooms) & 3rd floor (06 Rooms). Fire safety arrangements such as Smoke Management System, Fire Extinguishers, First-Aid Hose Reel, MOEFA, Internal Hydrant, Pumping Arrangement, Overhead Tank, and Exit Sign etc. However, following shortcomings were observed:-

1. Fire Check Door found removed at some places.
2. Carbon Monoxide (CO) detectors not provided.
3. Terrace pump of 450 LPM & 180 LPM is provided but not on auto mode.

In view of above shortcomings, the application for Renewal Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. Sh. Amandeep Mahindru, M/s Aman Palace, A-40, Vishal, Enclave, Rajouri Garden, New Delhi- 110026.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027.