

2114

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/ 2022/354

Dated:-17/05/2022

To,

The Manager,
Ashoka Continental Guest House,
8370, Arakashan Road,
Pahar Ganj, New Delhi.

**Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Ashoka Continental Guest House,
8370, Arakashan Road, Pahar Ganj, New Delhi. ID No. 2022041206649 dated 13/04/22.**

Sir,

This has a reference to on line ID No. . ID No. 2022041206649 dated 13/04/22 on the subject cited above. In this regard, it is to inform you that the site was visited by the officers concerned of this department on dated 05.05.22 in presence of **Manager** and observed that the Fire check door not provided on the staircase as per Gazette Notification dated 27.05.2019.

Therefore, you are requested to comply the same for further consideration in the matter.

Yours faithfully,


13/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.