

1/2

c-5

c59



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZI/362

Dated:-17/05/2022

To,

The Manager,  
M/S Chopra International Guest House,  
4058-4060, Pahar Ganj, New Delhi.

**Sub: Regarding renewal of FSC in r/o M/S Chopra International Guest House, 4058-4060, Pahar Ganj, New Delhi. (ID no. 2022010500305 dated 05.01.22)**

Sir,

This has reference to your mail id <hotelchopra.int@gmail.com> dated 03.04.22 on the subject cited above. In this regard, it is to inform you that the site was visited by the officer concerned of this department on dated 05.05.22 in presence of Manager and observed that Smoke management not installed as per gazette notification 27.05.2019.

Therefore, you are requested to submit the compliance as per gazette notification 27.05.2019 for further consideration in the matter.

Yours faithfully,



**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

1. The Addl. Commissioner of Police (Lic.) First floor, PS Defense Colony, New Delhi.

c-55

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No.F6/DFS/MS/EH/NDZ/2022/191

Dated: 04/03/2022

To

The Manager,  
M/S Chopra International Guest House,  
4060, Kaseruwalan, Pahar Ganj, New Delhi.

**Sub:** Regarding grant of FSC in r/o M/S Chopra International Guest House, 4060, Kaseruwalan, Pahar Ganj, New Delhi. ID NO. 2022010500305 dated 05.01.22.


Sir,

This has a reference to online ID No. 2022010500305 dated 05.01.22 & email [hotelchopra.int@gmail.com](mailto:hotelchopra.int@gmail.com) dated 06.01.2022. on the subject cited above, it is to inform you that the site was visited by the officer concerned of this department on dated 28.02.22 in presence of manager and following shortcomings were observed: -

- 1) Terrace pump is not provided with auto start provision.
- 2) PA system is not provided.
- 3) Building plans is not signed by owner himself.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcoming for further consideration in the matter.

Yours faithfully

  
373122

**(Dr. S.K. Tomar )**  
Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:-**

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.