

C 103

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/94/408

Dated 30/05/2022

To,

The Manager,
Hi Life Guest House,
8280-41, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o Hi Life Guest House, 8280-41, Arakashan Road, Pahar Ganj, New Delhi ID No. 2022042508229 dated 25.04.22

Sir,

This has reference to your ID No. **2022042508229** dated **25.04.22**, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned department on 23/05/2022 in the presence of **Manager** and the following shortcomings were observed:-


1. Hose reel found non functional.
2. Pump found non functional and also not in auto mode provision.

In view of above, the Fire Safety Certificate (FSC) cannot be issued. Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully,


26/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service


29/5

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.