

C117

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/94/409

Dated:-30/05/2022

To

The Manager  
M /S Sahni Guest House,  
F-14, D.B. Gupta Market, Karol Bagh,  
New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Sahni Guest House located at F-14, D.B. Gupta Market, Karol Bagh, New Delhi.

Sir,

This has reference to online ID No. 2022040405468 dated 05/04/2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 18/05/2022 in the presence of Mr. **Vinod Yadav** and following shortcomings were observed:-

1. Fire check doors are not provided as per gazette notification dated 27.05.2019.
2. Exhaust fans not provided as per gazette notification dated 27.05.2019.
3. Hose reel not covering entire area.
4. PA system found non functional.
5. All floors building plan not uploaded on the portal.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

  
27/5/22

**(Dr. S.K. Tomar)**  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi