

C 76

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/GH/NDZ/2022/ 364

Dated:- 17.05.2022

To

The Manager,
M/S Today International Guest House,
3/11, D.B.G. Road, Pahar Ganj,
New Delhi.

Sub: Regarding grant of FSC in r/o M/S Today International Guest House, 3/11, D.B.G. Road, Pahar Ganj, New Delhi. ID No - 2022042107901 dated 21.04.2022.

Sir,

This has a reference to your ID No - 2022042107901 dated 21.04.2022 on the subject cited above, it is to inform you that the site was visited by the officer concerned of this department on dated 09.05.22 in presence of **Mr. Ajay** and observed that the fire check door on the staircase not provided as per Gazette Notification dated 27.05.2019..

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the same for further consideration in the matter.

Yours faithfully


13/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony,
New Delhi.