

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/2022/SZ/ 12 91

Dated: 06/06/2022

To

The Chief Development Officer-DIAL,
New Urban Bhawan, Opposite –Terminal-3,
IGI Airport, New Delhi 110037

Sub: Regarding issuance of Fire Safety Certificate in r/o BSF Aircraft Hanger & U/G Fire Pump House, IGI Airport, New Delhi 110037.


Sir,

This is in reference to with Gmail of dated 09-05-2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Mr. Anuj Chauhan (L&T Engg. Department) on 26/05/2022 & the observations/ shortcomings noticed during the visited are listed below:-

1. Foam flooding system provided for the protection of Aircraft Hanger is not working.
2. The Fire fighting pumps are not on auto mode.

Keeping in view of above observations, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to: -

1. T S Raju (Chief Engineer/DIG) BSF Aircraft Hanger & U/G Fire Pump House, IGI Airport, New Delhi 110037.
2. The AGM/ Mechanical, DIAL, New Udaan Bhawan , Opp. T-3, IGI Airport, New Delhi