

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/EH/2022/ 345

Dated: 23/05/2022

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor,
Police Station, Defence Colony,
New Delhi.
adlcp.lic-dl@nic.in

Subject: Regarding inspection report in r/o M/s Jungle Jamboree Located at A-23, Vishal Enclave, Rajouri Garden, New Delhi -110027.

Sir,

Please refer to your application no. 2022040706008 dated 12/04/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 04/05/2022 in the presence of Sh. Harish and observed that the shortcomings already communicated by this department vide letter No.F6/DFS/MS/WZ/2021/586 dated 22/02/2021 & F6/DFS/MS/WZ/2021/490 dated 02/11/2021, is still not complied.


In view of above, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy to:

1. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.
Email Id : - (dhowest zone@gmail.com)
2. Sh. Harish, M/s. Jungle Jamboree Located at A-23, Vishal Enclave, Rajouri Garden, New Delhi -110027.


14/5/22

215

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

No. F6/DFS/MS/WZ/2021/490

Dated: 02/11/2021

To,

The Joint Commissioner (Lic.),
1st Floor, Defence Colony Police Station,
Defence Colony, New Delhi.

Subject: Inspection report in respect M/s. Jungle Jamboree, FF, A-23, Vishal Enclave, Rajouri Garden, Delhi- 110027.

Sir,

This is in reference to the online application received through MHA portal vide ID-2021033011755 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 06.10.2021 in the presence of Sh. Sandeep (manager) to check the provisioning of fire safety arrangements provided in the building. During the course of inspection, it was observed that the said restaurant is running at 1st floor of a building comprised of Basement, Ground, mezzanine, first floor, mezzanine and second floor, served by single staircase having width 1.30-1.50 mts. No fire safety arrangements found provided except few fire extinguishers. However, following fire safety arrangements are required: -

1. Two nos. of staircases having width of 1.5 mts each.
2. Width of door size is less than required width of 1.5 mts each.
3. Terrace Fire pump capacity 450 is required.
4. Overhead tank capacity 20000 lts is required.
5. Down comer system is required.
6. Exit signages on the places mentioned during the inspection are required.
7. MOEFA & MCP are required.
8. Lift shall be segregated with Fire Check Door.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. The licensing issuing authority /statutory authority is requested that premises should not be allowed to run till its provide all necessary fire safety arrangements.

Yours faithfully

(Atul Garg)
Director

Delhi Fire Service

Copy to: -

1. The Deputy Health Officer, South MCD, Shivaji Enclave, Raja Garden, New Delhi.
2. The owner/occupier, M/s. Jungle Jamboree, FF, A-23, Vishal Enclave, Rajouri Garden, Delhi- 110027.