

221

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2022/SZ/374

Dated 03/06/2022

To

The Dy. Health Officer, SDMC,  
Public Health Department,  
Aurobindo Marg, South Zone,  
Green Park, Delhi- 110016.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s Sly Granny (A Unit of Azure Hospitality Pvt Ltd) located at 1st & 2<sup>nd</sup> Floor, Khan Market, New Delhi 110003

Sir,

This has reference to with MHA Portal ID 2022041907601 dated 19/04/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 28.05.2022 in the presence of Mr. Sachin (Manager) to verify the fire safety measures installed in the building and observed that the restaurant running at 1st and 2nd upper floor of the building. During inspection, following points were observed:

- 1 There is one staircase having width of 1.0 mtr against the required two staircase having width of 1.50 mtr each respectively.
- 2 There is one exit door having width of 1.0 mtr against the required two door having width of 1.50 mtr each respectively.
- 3 Overhead tank capacity 5,000 ltrs provided against the required capacity 20,000 ltrs.
- 4 Exit sign not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

Copy to:

1. M/s Sly Granny (A Unit of Azure Hospitality Pvt Ltd) located at 1st & 2<sup>nd</sup> Floor, Khan Market, New Delhi 110003

4/20/22 10:38 AM  
LIG File No. 470, First