

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/Banquet/WZ/2022/ 81

Dated: - 03/06/2022

To,

The Dy. Health Officer, Keshav Puram Zone,
NDMC, Public Health Department,
A-1 Block Keshav Puram Zone, Delhi.

Sub:- Renewal of Fire Safety Certificate in respect of M/s. Blessing the Banquet Hall, located at GF, Plot No.- 09, Road No. 42, Community Centre, Pitampura, Delhi- 34.

Sir,

This has reference to your online application received through MHA portal vide ID-2022040806223, on the subject cited above. In this connection it is to inform you that the above said assembly building has been inspected by the officer concerned of this department on 20.05.2022 in presence of Smt. Reena (Manager), to check the fire safety arrangements already provided in the building.

During the course of inspection, it was observed that the banquet hall is running at ground floor in a building comprised of basement, ground and first floor (temporary shed). Fire safety arrangements such as fire extinguishers, hose reel, down comer system, sprinkler system, MOEFA, terrace pump etc. found provided. However, following shortcomings have been observed:

1. Banquet hall found operational in basement & ground floor and kitchen in first floor with temporary shed. whereas banquet hall is permitted only in ground floor.
2. Additional temporary construction on first floor shall be demolished.
3. Smoke Management system in basement floor found removed.
4. Hose reel hose, P.A. system, MOEFA, down comer system, sprinkler system in basement & ground floor are provided but not functional.
5. Terrace pump capacity 900 LPM is provided but not functional.
6. Overhead water storage tank capacity 6600 lts is provided against required 25000 lts.
7. Exit signage's removed at some places.

In view of above shortcomings, the application for renewal of fire safety certificate is not considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety measures shall be at the risk and liabilities of the owner/occupier.

Yours faithfully,

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. Sh. Gaurav Vij, M/s. Blessing Banquet Hall, Plot No. 09, Road No. 42, Community Centre, Pitampura, Delhi-110034,