



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SEVRVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/2022/SZ/ 387

Dated:- 26/05/2022

To

The Joint Commissioner of Police, (Lic/Branch)  
1<sup>st</sup> Floor, Defence Colony Police Station,  
New Delhi 110049.

Sub: - Regarding Issuance of fire Safety Certificate in r/o Hotel South Gate located at C-18,  
Green Park, Extension, New Delhi 110016.

Sir,

This has reference to the MHA Portal ID No 2022040605745 dated 07/04/2022, on the subject cited above. In this connection, this is to inform you that the above mentioned site was visited by the officer from Delhi Fire Service along with on 07/05/2022 and observed that the management of building has added 03 Guest rooms at ground level whereas as per the earlier building profile for guest house running at 1<sup>st</sup> to 3<sup>rd</sup> Floor with (08 Guest room each) total 24 Guest Rooms. Hence there is a material changed in the building Vis a Vis of FSC issued by this department vide letter of even no 905 dated 29/04/2019.

The management is here by advised, either you may restore the earlier composition of building profile or otherwise submits application for sanction of building plans on common application form (CAF) with present floor wise occupancy, on the scales as mentioned in UBBL 2016, for further consideration in the matter.

Keeping in view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/ premise in absence of requisite fire safety certificate shall be at the risk and liability of owner/ occupier. The statutory authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR

Copy to:

1. The Authorized Signature, Hotel South Gate located at C-18, Green Park, Extension,  
New Delhi 110016.