

C-78

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/GH/NDZ/2022/ 385

Dated:-26/05/2022

To,

The Manager,
City Palace Guest House,
2014/7, Chuna Mandi, Pahar Ganj,
New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S City Palace Guest House at 2014/7, Chuna Mandi, Pahar Ganj, New Delhi. Online ID No. 2021101123947 dated 12.10.21.


Sir,

This has reference to on line ID No. 2022042708533 dated 24.04.2022. on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 17/05/2022 in the presence of **Manager** and following shortcomings were still not complied: -

1. Fire check door at staircase is not provided as per gazette notification dated 27.05.2019.
2. Smoke management is not provided as per gazette notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


23/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.

13/5
Addl. C.

