

C-90

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/410

Dated:- 30.05.2022

To

The Manager
M/S Elegance Guest House,
7885/34, Arakashan Road,
Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Elegance Guest House located at, 7885/34,
Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022041607224 dated 16.04.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 19/05/2022 in the presence of **Sh. Satish** and following shortcomings were observed:-

1. Fire check door at staircase are not provided as per gazette notification dated 27.05.2019.
2. Smoke management is not provided as per gazette notification dated 27.05.2019.
3. CO detectors are not provided as per gazette notification dated 27.05.2019.
4. Fourth floor building plan is not submitted by owner/architect.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully


27/5/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi