

C/90

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2022/SZ/ 346
To

Dated: 23/05/2022

The Dy. Health Officer, South MCD,
Public Health Department,
Green Park, New Delhi 110016.

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s Fat Jar Café & Market,
(Delhi Delly LLP) at Ground Floor, A-7, Kailash Colony, New Delhi- 110048

Sir,

This is in reference to with MHA Portal ID 2022033104713 dated 31/03/2022 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04/05/2022 in the presence of Sh. Deepak Mehra (Owner) and observed that the shortcoming intimated vide letter of even no. 876 dated 11/12/2019 has not been complied yet. (Copy Enclosed for ready reference).

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)

SM

CP-67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/SZ/EH/2019/ 7369

Dated: 11/12/19

To

The Joint C.P. (Lic.),
1st Floor, P.S. Defence Colony,
New Delhi - 110049

Sub: Issue of Fire Safety Certificate in r/o M/s Fatjar Café & Market, GF, A-7, Kailash Colony, New Delhi- 110048

Sir,

This is in reference to your letter no. 31855/Jt.CP/EH(DA-X)/New Delhi dated 14/08/2019, received in this department through outdoor diary no. 17911 dated 21/08/2019 on the subject cited above. The premise was inspected by the concern nominated authority of this department in presence of Sh. Deepak Mehra (Owner) on 05/11/2019 to ascertain the availability and operability of fire protection and fire safety measures. During inspection, following points were observed:

1. Width of Exit doors is not meeting the requirement.
2. The First-Aid Hose Reel is not provided.
3. The MOEFA system is not provided.
4. The Internal Hydrant is not provided.
5. The Overhead water storage & terrace pump in conformity with Table-7, NBC-IV, of 2016 is not provided.
6. The required illuminated exit signage not provided.

Keeping in view of above, the Fire Safety Certificate cannot be issued at this stage in the interest of public safety.

Yours faithfully,


(Vipin Kental)
Chief Fire Officer

Copy to: -

M/s Fatjar Café & Market, GF, A-7, Kailash Colony, New Delhi- 110048

