

c. 31

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2022/SZ/376

Dated: 03/06/2022

To,

The Dy. Health Officer, South Zone,
Public Health Officer,
Aurobindo Marg, SDMC,
Green Park Zone, New Delhi 1100016

Subject: Inspection report of M/s JDGHENT KRII PRIVATE LIMITED, Flat No.-23, 1st Floor & 2nd Floor, Khan Market, New Delhi-110003.

Sir,

This has reference to with MHA Portal ID-2022021402194 dated 16/02/2022 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 28/05/2022 in the presence of Sh. Ajad Singh (Maintenance) to verify the fire safety measures installed in the building and observed that the restaurant running at 1st & 2nd floor of the building. During inspection, following points were observed:

1. Only one staircase of width 1.00mtr is provided against required of 2 no. staircases having width 1.50m each.
2. Only one exit door of width of 1.0 mtr is provided against required of 2 no. door having width of 1.50 mtr each.
3. Fire fighting pumps are not on auto mode.
4. Over Head Tank capacity of 5,000 ltrs is provided against requirement capacity of 20,000 ltrs
5. Exit Signage not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR.

Copy to:-

1. The Joint Commissioner of Police (Lic), 1st Floor, PS Defence colony, New Delhi-110049.
2. M/s JDGHENT KRII PRIVATE LIMITED, Flat No.-23, 1st & 2nd Floor, Khan Market, New Delhi-110003