GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/GH/439

Dated:-03./06/2022

To

The Manager M/S Hans International Guest House, 7965, Gali no- 6, Arakashan Road, Pahar Ganj, New Delhi.

Sub: Regarding issuance of FSC in r/o M /S Hans International Guest House,7965, Gali no- 6, Arakashan Road, Pahar Ganj, New Delhi.

Sir,

This has reference to online ID No. 2022042308144 dated 23.04.2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 23/05/2022 in the presence of **Manager** and following shortcomings were observed:-

- 1. Smoke management are not provided at each floor as per gazette notification dated 27.05.2019.
- 2. PA system found nonfunctional.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully

(**Dr. S.K. Tomar**) Dy. Chief Fire Officer Delhi Fire Service

Copy to :-

 The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi