

c 95

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/GH/NDZ/2022/ 434

Dated: 03/06/2022

To,

The Manager,
Hare Rama Guest House,
T-416 & T-298, Main Bazar,
Pahar Ganj, New Delhi.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Hare Rama Guest House located at T-416, & T-298, Main Bazar, Pahar Ganj, New Delhi. Online ID No. 2022041306898 dated 13.04.22.

Sir,

This has reference to ID No. 2022041306898 dated 13.04.22, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 25/05/2022 in the presence of Mr. Jeewan and following shortcomings were still not complied: -

1. Fire check door at staircase is not provided as per gazette notification dated 27.05.2019.
2. CO detectors are not provided as per gazette notification dated 27.05.2019.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcomings for further consideration in the matter.

Yours faithfully,


7/6/22

(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Addl. Commissioner of Police (Lic.), First floor, PS Defence Colony, New Delhi.