

e 79

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2022/44/435

Dated:-03/06/2022

To,

The Manager,
Hotel Lord Krishna Dx. Inn,
1171-75, 6, Tooti Chowk, Main Bazar,
Pahar Ganj, New Delhi.

Sub: Regarding renewal of FSC in r/o Hotel Lord Krishna Dx. Inn, 1171-75, 6, Tooti Chowk,
Main Bazar, Pahar Ganj, New Delhi.

Sir,

This has reference to your online id no.2022040806229 dated 08/04/2022 on the subject cited above. In this regard, it is to inform you that the site was re-inspected by the officer concerned department on 25/05/2022 in the presence of Mr. Pankaj and the following shortcoming is observed:-

1. Smoke Management System are not provided as per gazette notification dated 27.05.2019.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully



(Dr. S.K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

✓

Copy to :-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,
New Delhi