GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

F.6/DFS/MS/GH/SZ/2022/446

Dated: 07 06 2021

To

The Owner/Occupier, Jewel Palace guest house, 2622-27, Gali No. 3, Bank Street, Karol Bagh, New Delhi- 110005.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Jewel Palace guest house located at 2622-27, Gali No. 3, Bank Street, Karol Bagh, New Delhi- 110005. Sir.

Please refer to your Online Application No. 2022040104874 dated 01.04.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 27.05.2022 in the presence of Sh. Sanjev Kumar Narang, Manager, to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus four upper floors. Guest house served by 01 staircases having width 1.25 mts from ground to terrace floor. Fire safety arrangements such as first aid hose reel, fire extinguishers, D.G.Set etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building:-

1. Carbon Monoxide detector found not provided.

In view of the above as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019. The FSC issued vide letter no. F.6/DFS/MS/GH/SZ/2019/2334 dated 18.12.2019 stands null and void. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully

(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to :-

The Joint. Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi- 110049.